

Government of Jammu and Kashmir  
State Crime Branch Headquarters J&K  
Panjthirithi 180001 Jammu

**NOTICE INVITING SHORT TERM TENDER**

For and on behalf of Governor of J&K State, Short Term Tender affixed with revenue stamp of Rs.5/-are invited from approved, authorized dealers and reputed suppliers for supply of 3 KVA AVR's with isolation transformer for use in various offices of J&K Police. The tenders should reach the office of **Inspector General of Police State Crime Branch J&K Jammu (Panjthirithi CPO Chowk Jammu)** on or before **15.03.2016** up to 1200 Hrs. Tenders will be opened on **the same day** at 1400 hrs in presence of tenderers who may wish to be present on opening. The terms and conditions are as per annexure "A" and specification is as per annexure "B" of this NIT. The information can also be had from Website ([www.crimebranchjkipolice.nic.in](http://www.crimebranchjkipolice.nic.in)) including that of the office of Inspector General of Police State Crime Branch J&K at Jammu as per the dates given above on all working days during office hours.

SD/-

Inspector General of Police  
State Crime Branch J&K,  
Jammu.

No. CHQ/5067-ABC  
Dated:-09 /03/2016.

Copy to the:-

1. Director General of Police J&K Jammu for favour of information please.
2. Director Information J&K Jammu for information please.
3. Dy. Director Information Jammu, with the request that NIT be got published in Srinagar/Jammu based leading News papers.
4. Incharge Computer section CHQ, the NIT be placed on website of J&K Police.
5. Office file.

SD/-

Inspector General of Police,  
State Crime Branch J&K,  
Jammu.

## Terms and conditions

<p>(I) The tenders should be sent by registered post or can be delivered personally at State Crime Branch Hqr's. J&amp;K, Jammu, near CPO Complex Panjtirthi Jammu up to 14-03-2016. The tenders received after expiry of prescribed date &amp; time will not be entertained, no telegraphic/conditional tender will be accepted.</p>
<p>(II) The rates should be quoted only for the items, specified. The rates quoted for items other than the SBD will not be accepted. The <b>brand/make/model /warranty period</b> should be mentioned.</p>
<p>(III) The tender should be computerized or typed. Tender filled in by pen or pencil or otherwise, shall not be considered. No overwriting would be acceptable.</p>
<p>(IV) The Tenderer shall be responsible for the proper packing so as to avoid any damage under normal condition of transport by Rail, Road or Air during delivery of the item at destination. In the event of any loss, damage, breakage or any shortage, the tenderer shall be liable to make good such loss and shortage found at the checking/survey of item. No extra cost on such account would be admissible.</p>
<p>(V) The tenderer, whose tender is accepted shall arrange the supply within a period of 30 days from the date of placing supply order.</p>
<p>(VI) 100% payment will be made by W.D.C bill or Bank draft, if so desired after the supplies are received in full, duly surveyed, and accepted by the survey committee nominated for the purpose. Out dated/defective items will be rejected forthwith.</p>
<p>(VII) The intending tenderers will have to send earnest money @ 2% of value of quoted items in shape of CDR/FDR valid for 6 months from any Nationalized bank pledged to <b>The Staff officer to Inspector General of Police Crime Branch J&amp;K</b>, without earnest money the tender will not be accepted.</p>
<p>(VIII) The document for being an authorised dealer / reputed supplier be enclosed with the quotations. Literature/ original catalogue should be furnished with the equipment wherever applicable.</p>

SD/-

Inspector General of Police,  
State Crime Branch J&K,  
Jammu.

## Annexure "B"

### Specifications of 3 KVA AVR with Isolation transformer

1.	Input Voltage	70 v to 250 V AC
2.	Output Voltage	220 V $\pm$ 10%
3.	Output frequency	50 Hz
4.	Input frequency	50 Hz $\pm$ 5%
5.	Correction of speed	100 V/Sec
6.	Transformer winding	Copper
7.	Type of Switching	Static Switching
8.	Metering	LCD Meter to show I/P Voltage, Output Voltage and current
9.	Indicator	Mains, Output
10.	Protection	Input High/Low Voltage Cut off Output High/Low Voltage Cut off
11.	Bypass Switching	Auto/Manual i.e., Back to Back SCR Modules.
12.	Type of Cooling	Air Cooled

SD/-  
Inspector General of Police,  
State Crime Branch J&K,  
Jammu.